TEST CERTIFICATE

Issued to:	Hyundai Electric & Energy Systems Co., Ltd. 75, Yulgok-ro, Jongno-gu, Seoul, Republic Of Korea
For the product:	Moulded case circuit breaker
Trade name:	Hyundai
Type/Model:	HGM1250S; HGM1000S
Ratings:	In: 1000 A, 1250 A; Ue 380/415 Vac; Ics = 65 kA at 380/415 Vac; Icu = 70 kA at 380/415 Vac Icw = 15 kA 1 s*
Manufactured by:	Federal Elektrik 1. Organize Sanayi Bolgesi 1. Yol No: 25 Hanli 54000 Arifiye / Sakarya Turkey
Requirements:	IEC 60947-2:2016, IEC 60947-2:2016/A1:2019
Remarks:	* Clause 8.3.6.3 and 8.3.6.6 only

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 2254797.02, dated 2021-05-17.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 25 May 2021 Number: 2254797.101

DEKRA Certification B.V.

H.R.M. Barends
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed